



RECEIVED DIVISION OF DAVAO DEL NORTE  
RECORDS SECTION  
**RECEIVED**  
Date: 28 SEP 2022 4:21 PM  
By: \_\_\_\_\_

Republic of the Philippines  
**Department of Education**  
REGION XI  
SCHOOLS DIVISION OF DAVAO DEL NORTE

---

**Office of the Schools Division Superintendent**

DIVISION MEMORANDUM  
OSDS – 2022 – 056

To: Dr. Ana N. Redaniel  
Public Schools District Supervisor/Officer In charge of Sawata Ernandcor  
Central Elementary School


Subject: Occupancy of the 3 story 12 Classroom School Building of Sawata  
Ernandcor Central Elementary School

Date: September 27, 2022


---

Please be advised of the herein recommendation of the Division Engineer, Engr. Elielou P. Jumawan, as regards the stability and structural integrity of the 3 story 12 classroom building at Sawata Ernandcor Central Elementary School.

With the foregoing, the said building may now can be occupied immediately as recommended.

  
**DEE D. SILVA, DPA, CESO V**  
Schools Division Superintendent

Enclosed: As stated  
SGOD/cbg

  
Republic of the Philippines  
**Department of Education**  
REGION XI  
SCHOOLS DIVISION OF DAVAO DEL NORTE

---

September 26, 2022

**RAMEL M. PILO**


Chief, SGOD  
This Division  
Mankilam, Tagum City

Sir:

This has reference to the recently conducted rebound hammer test by the engineers of the Department of Public Works and Highways (DPWH) in Sawata Ernandcor Central Elementary School located in San Isidro District. This was done in order to determine the average concrete compressive strength of the structural members of the Three (3) Storey Twelve (12) Classroom School Building. Thus, this determines the stability and structural integrity of the building.

In their letter to the OIC School Head Mrs. Ana N. Redaniel (attached), they had informed her that the building had passed the design strength since the average concrete compressive required is 27.6 Mpa while the buildings results ranges from 32.6Mpa to 41.30 Mpa.

In line with this the undersigned declares that the mentioned building is safe for occupancy and school children may now occupy the building.

  
**ELIELOU P. JUMAWAN**  
Division Engineer

